LPCB

This is to Certify

GULF SECURITY TECHNOLOGY CO., LTD.

No 80 Changjiang East Road, QETDZ, Qinhuangdao, Hebei Province, 066004 China

is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix.

I-9403, C-9403 and I-9406 Sounder strobes

which have complied with the requirements of the following:

EN 54-3: 2001 + A1: 2002 + A2: 2006

Certificate No: 548e

Issue Number: 09

Date of Issue: 20 March 2013

Signed for and on behalf of LPCB

M McCULLAGH







Appendix to Certificate

Certificate No: 548e

GULF SECURITY TECHNOLOGY CO., LTD.

Certified Products

LPCB Ref. No.

C-9403

Conventional sounder strobe (Shallow and Deep Bases)

548e/01

Note

28:

1) Meets the requirements of EN 54-3: 2001

1) Meets the requirements of EN 54-3: 2001 at the following tones:

Tone 14 2400Hz - 2900Hz @ 3Hz Tone 16 500HZ - 1200Hz, 3.75s on / 0.25s off

2) Approved in both normal and power saving mode

3) The visual alarm function is not in the scope of this approval.

1-9403

Intelligent sounder strobe (Shallow and Deep Bases)

548e/02

Notes:

1) Meets the requirements of EN 54-3: 2001 at the following tones:

Tone 14 2400Hz - 2900Hz @ 3Hz

Tone 16 500HZ - 1200Hz, 3.75s on / 0.25s off

Pre Alarm 800Hz, 1s on / 1s off

2) Approved in both normal and power saving mode

3) The visual alarm function is not in the scope of this approval

4) Approved with single address and dual address (pre-alarm and main alarm).

For details of Cross-Listed products and alternative branding please see page 4

Appendix Issue No: 09

Page: 2 of 4

Date of Issue: 20 March 2013

Signed for and on behalf of LPCB





M McCULLAGH



Appendix to Certificate

Certificate No: 548e

GULF SECURITY TECHNOLOGY CO., LTD.

Certified Products

LPCB Ref. No.

I-9406

Analogue Addressable Indoor sounder Beacon Base (I-9102,I-9103 detectors and DZ-03 base)

548e/03

Notes:

1) Meets the requirements of EN 54-3: 2001 at the following tones:

Tone 14 2400Hz - 2900Hz @ 3Hz Tone 16 500HZ - 1200Hz, 3.75s on / 0.25s off

- 2) Approved in both normal and power saving mode3) The beacon functionality is not approved to EN 54-23
- 4) Approved with P-9907 cover plate
- 5) Approved with I-9103 heat detector and I-9102 smoke detector

Bases:

Shallow Base Deep base DZ-03 Standard base

For details of Cross-Listed products and alternative branding please see page 4

Appendix Issue No: 09

Page: 3 of 4

Date of Issue: 20 March 2013

Signed for and on behalf of LPCB





M McCULLAGH

LPCB

Appendix to Certificate

Certificate No: 548e

GULF SECURITY TECHNOLOGY CO., LTD.

ALTERNATIVE MODEL NUMBERS AND LABELLING

LPCB No.	Model No.	Alternative Model No.	Labelled	Distributors Ref. Ref/Cert. No.
548e/01	C-9403	GS403C FX9403 S-C481 C-9403 AVD-C403	Group 4 FIREX-UK ⁽¹⁾ Shield GST Multron	548e-(cl-2) 548e-(cl-3) 548e-(cl-4) 548e-(cl-5) 548e-(cl-6)
548e/02	I-9403	GS403I FX9403I S-A491 I-9403 AVD-A403	Group 4 FIREX-UK ⁽¹⁾ Shield GST Multron	548e-(cl-2) 548e-(cl-3) 548e-(cl-4) 548e-(cl-5) 548e-(cl-6)

⁽¹⁾ Emirates Fire Protections Equip. Factory. TR. Section

For details of Cross-Listed products and alternative branding please see page 4

Appendix Issue No: 09

Page: 4 of 4

Date of Issue: 20 March 2013

Signed for and on behalf of LPCB





M McCULLAGH