

## Certificate of Product Approval

Certificate Number: 548q

Issue: 12

### Gulf Security Technology Co., Ltd

No. 80 Changjiang East Road  
QETDZ  
Qinhuangdao, Hebei Province  
066004  
China



is certified by BRE Global Ltd. and is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

#### Products

##### Multi-Sensor/Multi Criteria Detectors

C-9101

I-9101

DC-9101E

DI-9101E

DC-9101E-B

DI-9101E-B

(refer to Appendix for details)

#### Standards

EN 54-5:2000 + A1:2002

EN 54-7:2000 + A1:2002 + A2:2006

CEA 4021: July 2003

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for BRE Global Ltd

P Halligan

Verifier

28 May 2021

Date of Issue

2 August 2000

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX  
T: +44 (0)333 321 8811 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



## Appendix to Certificate No: 548q

Issue: 12

### Gulf Security Technology Co., Ltd

Certified Product	Description	LPCB Ref.No.
C-9101	Conventional Optical Smoke and Heat Multisensor Detector (P-9907, DZ-03D & DZ-03 Bases) Notes: 1. Meets the requirements of EN 54-7: 2000 for sensitivity setting Mode 1 2. Meets the requirements of EN 54-5: 2000 for Class A2R	548q/01
I-9101	Intelligent Optical Smoke and Heat Multisensor Detector (DZ-03 Base) Notes: 1. Meets the requirements of EN 54-7: 2000 for sensitivity setting Mode 1 2. Meets the requirements of EN 54-5: 2000 for Class A2R	548q/02
DC-9101E	Conventional Combination Heat / Photoelectric Smoke Detector (DB-01 & DB-01D Bases and DP-9907 Unit) Notes: 1. Meets the requirements of EN 54-7: 2000 at sensitivity level 1 (default) setting only 2. Meets the requirements of EN 54-5: 2000 for Class A2R	548q/03
DC-9101E-B	Conventional Combination Heat / Photoelectric Smoke Detector – Black Plastic (DB-01-B & DB-01D Bases and DP-9907 Unit) Notes: 1. Meets the requirements of EN 54-7: 2000 at sensitivity level 1 (default) setting only 2. Meets the requirements of EN 54-5: 2000 for Class A2R	548q/03
DI-9101E	Intelligent Combination Heat / Photoelectric Smoke Detector (DB-01 Base) Notes:	548q/04

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd

P Halligan  
Verifier

28 May 2021  
Date of Issue

2 August 2000  
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX  
T: +44 (0)333 321 8811 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)

LPCB is a Registered Trademark of the Building Research Establishment Ltd.




Appendix to Certificate No: 548q

Issue: 12

## Gulf Security Technology Co., Ltd

Certified Product	Description	LPCB Ref.No.
	1. Meets the requirements of EN 54-7: 2000 at sensitivity level 1 (default) setting only 2. Meets the requirements of EN 54-5: 2000 for Class A2R	
DI-9101E-B	Intelligent Combination Heat / Photoelectric Smoke Detector – Black Plastic (DB-01-B Base) Notes: 1. Meets the requirements of EN 54-7: 2000 at sensitivity level 1 (default) setting only 2. Meets the requirements of EN 54-5: 2000 for Class A2R	548q/04

### Bases

P-9907	Active EOL Base
DZ-03D	Diode Base
DZ-03	Standard Base
DB-01	Standard Base
DB-01-B	Standard Base – Black Plastic
DB-01D	Diode Base
DP-9907	Active End of Line Unit

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd

P Halligan

Verifier

28 May 2021

Date of Issue

2 August 2000

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX  
 T: +44 (0)333 321 8811 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)

LPCB is a Registered Trademark of the Building Research Establishment Ltd.




## Appendix to Certificate No: 548q

Issue: 12

### Gulf Security Technology Co., Ltd

#### Alternative Model No./Label

LPCB Ref No.	Model No.	Alternative Model No./Label	Cross-listed company	Cross-Listed Co Cert./ Ref No.
548q/01	C-9101	FX9101	FIREX Protection System Technology Ltd	548q-(cl-2)
548q/02	I-9101	FX9101I	FIREX Protection System Technology Ltd	548q-(cl-2)
548q/03	DC-9101E	SCC-9101E	SS Fire & Security SDN BHD	548q-(cl-3)
548q/03	DC-9101E	FX9101E	FIREX Protection System Technology Ltd	548q-(cl-2)
548q/04	DI-9101E	SCA-9101E	SS Fire & Security SDN BHD	548q-(cl-3)
548q/04	DI-9101E	FXI9101E	FIREX Protection System Technology Ltd	548q-(cl-2)

#### Bases

LPCB Ref No.	Model No.	Alternative Model No./Label	Cross-listed Company	Cross-Listed Co Cert./ Ref No.
548	DZ-03	DZ-03	FIREX Protection System Technology Ltd	548q-(cl-2)
548	DZ-03D	DZ-03D	FIREX Protection System Technology Ltd	548q-(cl-2)
548	P-9907	FX9907	FIREX Protection System Technology Ltd	548q-(cl-2)
548	DB-01	SE-DB-01	SS Fire & Security SDN BHD	548q-(cl-3)
548	DB-01D	SE-DB-01D	SS Fire & Security SDN BHD	548q-(cl-3)
548	DP-9907	SE-DP-9907	SS Fire & Security SDN BHD	548q-(cl-3)
548	DB-01	FX-01	FIREX Protection System Technology Ltd	548q-(cl-2)

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd

P Halligan

Verifier

28 May 2021

Date of Issue

2 August 2000

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX  
T: +44 (0)333 321 8811 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)

LPCB is a Registered Trademark of the Building Research Establishment Ltd.

