



# CONFORMITY CERTIFICATE OF EXPLOSION-PROOF

Certificate No.: CE20.2825

Name of Product: Zener Safety Barrier

Type of Product: GST-AS-200

Marking: [Ex ib Gb] II C

Technical Documents: Q/GST51-2015

Drawing No.: F2.909.1329、F2.909.1330

Note (s):

1. The certificate can represent model: GST-AS-300, GST-AS-200.
2. Safety barrier parameters:  
GST-AS-200(3-4) and GST-AS-300 (3-earthing)、(4-earthing):  
Um: 250V AC/DC, Uo: 28V, Io: 93mA, Po: 0.65W,  
Co: 0.083  $\mu$  F, Lo: 4mH.
3. The safety barrier must be earthed, The cross-sectional area of grounding insulated wire is not less than 4mm<sup>2</sup>.

By verifying the drawings and technical documents and checking samples, the product complies with the following standards:

GB 3836.1-2010

GB 3836.4-2010

Issued to: Gulf Security Technology Co., Ltd.

Date of Expire: 2025-12-18

Date of Issue: 2020-12-18

Center seal



Director

Liu Hongguang

National Ex-Product Quality Supervision and Inspection Center(TianJin)  
( Supervision & Test Center of Ex- products of China Petroleum & Chemical Industry )

注: 本证仅对与送检样品一致的产品有效

Note: This certificate is only valid for the products that are in accord with sample(s) tested and verified.

中心地址:中国天津市丁字沽三号路 85 号

邮政编码:300131

电话/传真: 022-26651066 /26689116

Center Add: No.85 No.3 Road DingZiGu Tianjin China Post code: 300131

Tel/ Fax: 022-26651066/26689116

E-mail:pcec@pcec.com.cn

<http://www.pcec.com.cn>