



防爆合格证

CONFORMITY CERTIFICATE OF EXPLOSION-PROOF

证号
Certificate No. CE16.2158

产品名称
Name of Product

点型光电感应火灾探测器

型号及规格
Type of Product

DC-9102 (IS)

防爆标志
Marking

Ex ib II C T6 Gb

技术文件
Technical Documents

Q/GST C043.1-2011、Q/GST C043.2-2011

图号
Drawing No.

F3.780.934

备注
Note (s)

1. 本安参数: $U_i: 28VDC$, $I_i: 93mA$, $P_i: 651mW$, $C_i: 0\mu F$, $L_i: 0mH$ 。
2. 产品使用环境温度: $-10^{\circ}C \leq T_a \leq +55^{\circ}C$ 。
3. 此产品必须与安装在安全区的关联设备连接, 关联设备参数见使用说明书。

经对上述产品图样及技术文件的审查和样品的检验, 其符合以下标准

By verifying the drawings and technical documents and checking samples, the product complies with the following standards

GB3836.1-2010

GB3836.4-2010

发给: 海湾安全技术有限公司
Issued to:

本证失效日期: 2021-08-12
Date of Expire:

发证日期: 2016-08-12
Date of Issue:

中心印章
Center seal



中心主任
Director

刘红光

石油和化学工业电气产品防爆质量监督检验中心
Supervision & Test Center of Ex-products of China Petroleum & Chemical Industry

注: 本证仅对与送检样品一致的产品有效。

Note: This certificate is only valid for the products that are in accord with sample(s) tested and verified.

中心地址: 中国天津市丁字沽三号路 85 号

Center Add: No.85 No.3 Road DingZiGu Tianjin China Post code: 300131

E-mail: pcec@pcec.com.cn

邮政编码: 300131

电话/传真: 022-26651066 / 26689116

Tel/ Fax: 022-26651066/26689116

<http://www.pcec.com.cn>



CONFORMITY CERTIFICATE OF EXPLOSION-PROOF

Certificate No.: CE16.2158

Name of Product: Intrinsically Safe Conventional Photoelectric Smoke Detector

Type of Product: DC-9102(IS)

Marking: Ex ib II C T6 Gb

Technical Documents: Q/GST C043.1-2011, Q/GST C043.2-2011

Drawing No.: F3.780.934

Note (s):

1. Intrinsic safety parameters: U_i :28VDC, I_i :93mA, P_i :651mW, C_i :0 μ F, L_i :0mH.
2. Ambient temperature: $-10^{\circ}\text{C} \leq T_a \leq +55^{\circ}\text{C}$.
3. This product must be connected to the associated apparatus which is mounted in the safe area. For the parameters of the associated apparatus see the manual.

By verifying the drawings and technical documents and checking samples, the product complies with the following standards:

GB 3836.1-2010

GB 3836.4-2010

Issued to: Gulf Security Technology Co., Ltd.

Date of Expire: 2021-08-12

Date of Issue: 2016-08-12

Center seal



Director

Liu Hongguang

Supervision & Test Center of Ex- products of China Petroleum & Chemical Industry

Note: This certificate is only valid for the products that are in accord with sample(s) tested and verified.

Center Add: No.85 No.3 Road DingZiGu Tianjin China Post code: 300131

E-mail: pcec@pcec.com.cn

Tel/ Fax: 022-26651066/26689116

<http://www.pcec.com.cn>