



## CONFORMITY CERTIFICATE OF EXPLOSION-PROOF

Certificate No.: CE12.1341

Name of Product: Digital Flame-Proof Manual Call Point  
Type of Product: DI-9204 Exd  
Marking: **Ex d II B T6 Gb/DIP A20 TA,T6; Ex d II C T6 Gb/DIP A20 TA,T6**  
Technical Documents: Q/GST C053.1-2011, Q/GST C053.2-2011  
Drawing No.: F2.909.420, F2.909.422  
Note (s):  
1. Rated voltage: DC24V.  
2. Rated power:3W.  
3. IP degree:IP6X.  
4. An elastomeric sealing ring is used for the cable sealing when the Ex-marking is Ex d II B T6 Gb/DIP A20 TA,T6; a filling compound is used for the cable sealing when the Ex-marking is Ex d IIC T6 Gb/DIP A20 TA,T6.

By verifying the drawings and technical documents and checking samples, the product complies with the following standards currently valid in P.R.China:

GB3836.1-2010

GB3836.2-2010

GB12476.1-2000

Issued to: GULF SECURITY TECHNOLOGY CO., Ltd.

Date of Expire: 2017-07-09

Date of Issue: 2012-07-09

Center seal



Director

Liu Hongguang

Supervision & Test Center of Ex- products of China Petroleum & Chemical Industry

Note: This certificate is only valid for the products that are in accord with sample(s) tested and verified.

Center Add: No.85 No.3 Road DingZiGu Tianjin China Post code: 300134

Tel/ Fax: 022-26651066/26689116

E-mail: ccc@pcec.com.cn

<http://www.pcec.com.cn>