Notified Body No. 0832

BRE Global

BRE Global Limited
Bucknalls Lane, Garston, Watford, Hertfordshire, UK, WD25 9XX
Telephone: +44 (0)1923 664100 Fax: +44 (0)1923 664603
Email: enquiries@breglobal.com Web: www.breglobal.com

Certificate of constancy of performance,

0832-CPR-F0005

In compliance with Regulation 305/2011/EU of the European Parliament and of the council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

DC-9103E – Conventional Rate of Rise and Fixed Temperature Heat Detector

(For full product details and conditions of use refer to appendix)

Produced by or for

Gulf Security Technology Co. Ltd

No. 80 Chanjiang East Road QETDZ, Qinhuangdao Hebei 066004 China

and produced in the manufacturing plant(s)

Gulf Security Technology Co. Ltd

No. 80 Chanjiang East Road QETDZ, Qinhuangdao Hebei 066004 China

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

EN 54-5:2000 + A1:2002 - Heat Detectors - Point Detectors

under system 1 are applied and that

the product fulfils all the prescribed requirements set out above.

This certificate was first issued on 09 April 2014 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.

Martin McCullagh, Certification Manager On behalf of BRE Global Limited Date of issue: 09 April 2014

Issue number: 01

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions. To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email enquiries@breglobal.com.

Notified Body No. 0832

BRE Global

BRE Global Limited
Bucknalls Lane, Garston, Watford, Hertfordshire, UK, WD25 9XX
Telephone: +44 (0)1923 664100 Fax: +44 (0)1923 664603
Email: enquiries@breglobal.com Web: www.breglobal.com

Appendix to Certificate of constancy of performance 0832-CPR-F0005

Base:

DB-01 Standard Base
DB-01D Diode Base

DP-9907 Active End of Line Unit

Approved Classes:

A1R A2S BS



Martin McCullagh, Certification Manager On behalf of BRE Global Limited Date of issue: 09 April 2014

Issue number: 01

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions. To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email enquiries@breglobal.com.