

Certificate of constancy of performance,

0832-CPR-F0994

In compliance with Regulation 305/2011/EU of the European Parliament and of the council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

GST-IFP8 Intelligent 8 Loop, 140 Zone Analogue Addressable Control and Indicating Equipment

(For full product details and conditions of use refer to appendix)

Produced by or for

Gulf Security Technology Co., Ltd

**No. 80 Changjiang East Road
QETDZ
Qinhuangdao, Hebei Province
066004
China**

and produced in the manufacturing plant(s)

Gulf Security Technology Co., Ltd

**No. 80 Changjiang East Road
QETDZ
Qinhuangdao, Hebei Province
066004
China**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

EN 54-2:1997 + A1:2006 - Control and indicating equipment EN 54-4:1997 + A1:2002 + A2:2006 - Power supply equipment

under system 1 are applied and that

the product fulfils all the prescribed requirements set out above.

This certificate was first issued on 06 February 2015 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.



E Mattie-Suleiman, Certification Manager
On behalf of BRE Global Limited
Date of issue: 06 February 2015
Issue number: 01

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions.
To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email enquiries@breglobal.com.

Appendix to Certificate of constancy of performance 0832-CPR- F0994

Incorporating the following units:

SB-800/ F7.820.1238 Indication board
LCIFP8/ F7.820.1239 Loop board
PB-800/ F7.820.1311 Power board
ZP-800/ F7.820.1312 ZCP board
KB-800/ F7.820.1326 Keypad board
MB-800/ F7.820.1237 Main board
MO-800/ F7.820.1310 Mother board

Incorporating as optional modular units:

P-9935/ F7.820.1313 USB communication board
Optional language variants;
GST-IFP8-PT Portuguese language variant
GST-IFP8-HU Hungarian language variant
GST-IFP8-FR French language variant
GST-IFP8-IT Italian language variant
GST-IFP8-SP Spanish language variant
GST-IFP8-TK Turkish language variant

Certified with the following options with requirements from EN 54 Part 2:

7.8 Output to fire alarm devices
7.9.1 Output to fire routing equipment
7.9.2 Alarm confirmation input from fire routing equipment
7.10.1 Output type A
7.10.2 Output type B
7.11 Delays to outputs
7.12.1 Dependencies on more than one alarm signal - Type A
7.12.2 Dependencies on more than one alarm signal - Type B
7.13 Alarm counter
8.3 Fault signals from points
9.5 Disablement of each address point
10 Test condition



E Mattie-Suleiman, Certification Manager
On behalf of BRE Global Limited
Date of issue: 06 February 2015
Issue number: 01

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions.
To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email enquiries@breglobal.com.