

BRE Global Ireland

Notified Body No. 2831

www.breglobalireland.ie

BRE Global Assurance (Ireland) Limited DCU Alpha, Old Finglas Road Glasnevin, Dublin, D11 KXN4 Ireland T: +353 (0) 18824344 E: enquiries@breglobalireland.ie

Certificate of constancy of performance

2831-CPR-F0339

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

DI-9101E Intelligent Combination Heat / Photoelectric Smoke Detector

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trade

mark of:

Gulf Security Technology Co. Ltd No. 80 Chanjiang East Road

QETDZ, Qinhuangdao

Hebei 066004 China and produced in the manufacturing plant(s):

Gulf Security Technology Co. Ltd No. 80 Chanjiang East Road

QETDZ, Qinhuangdao

Hebei 066004 China

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-5:2000 + A1:2002 - Heat Detectors - Point Detectors EN 54-7:2000 + A1:2002 + A2:2006 - Smoke Detectors - Point Detectors

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 15 October 2019 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Date of First Issue: 15 October 2019

E. Mattie-Suleiman, Certification Engineer Date of Issue: 15 October 2019

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie.

BF1938i Rev.1.0 Page 1 of 2 © BRE Global Assurance (Ireland) Limited, 2019



BRE Global Ireland

Notified Body No. 2831

BRE Global Assurance (Ireland) Limited DCU Alpha, Old Finglas Road Glasnevin, Dublin, D11 KXN4 Ireland

T: +353 (0) 18824344 E: enquiries@breglobalireland.ie www.breglobalireland.ie

APPENDIX to Certificate of constancy of performance: 2831-CPR-F0339

DI-9101E Intelligent Combination Heat / Photoelectric Smoke Detector

Base:

DB-01 Standard Base

Approved Class:

A2R

E. Mattie-Suleiman, Certification Engineer,

Date of First Issue: 15 October 2019

Date of issue: 15 October 2019

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie.